

### **FM Cerificate of Compliance**

Pipe Hangers
SPR-Filbow Clamp
O.E.-Single Bossed Clamp
Filbow Clamp
TKN-Girder Clamp with cup point

valid for

Filbow Clamp pear shaped
Filbow Clampr with knurled nut
Single Bossed Clamp heavy duty without lining
Girder Clamp galvanised

This document is for informational use only and does not underly the actualization process.

This document can not be used for advertising or other purposes unless otherwise approved by MÜPRO in advance. All rights reserved. Subject to change.



# **Certificate of Compliance**

This certificate is issued for the following:

#### **PIPE HANGERS**

Product Designation	Hanger Rod Size, in. (mm)	Component Description	For Nominal Pipe Sizes, in.
SPR	3/8 (10)	Filbow Clamp	3/4 through 4
SPR	1/2 (12)	H H	5 through 6
O.E.	3/8 (10)	Single Bossed Clamp	3/4 through 4
O.E.	1/2 (12)	H H	3/4 through 6
Filbow Clamp	3/8 (10)	Filbow Clamp	3/4, 1, 1 1/4, 1 1/2, 2, 2 1/2, 3, 4 in. 44.5, 50, 57.0, 63.5, 70, 80, 100, 108 mm
Filbow Clamp	1/2 (12)	Filbow Clamp	5, 6 in. 133, 150, 159, 168.3 mm
Filbow Clamp	5/8 (16)	Filbow Clamp	8 in. 177.8, 193.7 mm
TKN-10	3/8 (10)	Girder Clamp with cup point	3/4 through 4
TK-12	1/2 (12)	"	3/4 through 8

#### **Prepared for:**

MÜPRO Services GmbH Hessenstrasse 11 65719 Hofheim-Wallau Germany



Member of the FM Global Group



## **Certificate of Compliance**

FM Approvals Class: 1951

Approval Identification: 3028091 (May 18, 2007), 3000277 (April 18, 2000), 1W3A9.AH

(September 7, 1993), 1W2A4.AH (October 8, 1993), 0P2A3.AH

(June 17, 1987)

Said Approval is subject to satisfactory field performance, continuing follow-up Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

Richard B. Dunne

Group Manager -Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

August 10, 2012

Date



Member of the FM Global Group