

# **FM Certificate of Compliance**

Swivel loop hanger type EHS

valid for

**Filbow clamp type EHS**

This document is for informational use only and does not underly the actualization process.  
This document can not be used for advertising or other purposes unless otherwise approved by MÜPRO in advance.  
All rights reserved. Subject to change.



# Certificate of Compliance

This certificate is issued for the following:

## Pipe Hanger Components for Automatic Sprinkler Systems

<i>Product Designation</i>	<i>Hanger Rod Size, in. (mm)</i>	<i>Component Description</i>	<i>For Nominal Pipe Sizes, in.</i>
EHS	3/8 (10)	Swivel Loop Hanger	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4
EHS	1/2 (12)	Swivel Loop Hanger	5, 6
EHS	5/8 (16)	Swivel Loop Hanger	8

### Prepared for:

Müpro Services GmbH  
Hessenstrasse 11  
65719 Hofheim-Wallau  
Germany

FM Approvals Class: 1951, dated April 2008

Approval Identification: PR451565      Approval Granted: November 8, 2018

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller", written over a horizontal line.

David B. Fuller  
VP, Manager-Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062



Member of the FM Global Group