

Single bossed clamps

heavy-duty version, with DÄMMGULAST® red, galvanised

Application

- Suitable combination for pipelines with dynamic loads with expansion points
- Suitable for fixings in industrial areas
- Suitable for fastening of drinking water and heating pipes as well as for thermical oil pipes
- Attachment of pipelines in increased temperature ranges
- For indoor use


Your advantages

- Proven two-part clamp with increased material cross-section
- Stronger fastening latches for high load capacity
- High strength all-round welding of the connecting nut
- DÄMMGULAST® Vibration control lining red, high-temperature resistant up to +200 °C
- Average sound level improvement up to 24 dB(A)
- Approved for the attachment of sprinkler systems by VdS





Features	fre protection certified certified with the certifi
Size	Max. recommended load [N]
1/2" - 3"	5,000
102 - 133 mm	5,830
≥ 5"	6,666



Connecting thread	Si	ze	Clamping range	VdS	Dimensions [mm]							Part no.	Sales unit	Pack unit
M	[inch]	[mm]	[mm]		b	s	b1	В	Н	H1	V			
M8	1/2"		20 - 26	Х	30	3	34	83	32	52	M8	124422	1	Pieces
	3/4"		25 - 28	Χ				88.3	34.5	57		124425	100	
	1"		30 - 35	Χ				91.5	36.5	61		124430		
	11/4"		40 - 43	Х				102.5	42	72		124434		
	11/2"		48 - 54	Χ				109.9	45.5	79		124438	50	
	2"		57 - 64	Χ				125.6	54	96		124442		
M10		70	68 - 72	Χ				133.6	59.5	105		124302		
	21/2"		72 - 80	Χ				144.4	62	110		124306		
		83	82 - 86	Χ				155	66.6	119.1		124311		
	3"		88 - 92	Χ				158.6	67.5	121		124315		
		102	99 - 103	Χ				170.4	73.6	133.2		124283		
	4"		108 - 118	Χ				184.2	80.8	147.6		124287		
M12		125	125 - 130	Χ	40	4	46	202.5	90	164		124331		
		133	131 - 137	Χ				211.5	96.5	177		124339	25	
	5"		138 - 144	Χ				217	97	178		124343		
		160	159 - 168	Χ				235	106	196		124347		
	6"		164 - 170	Χ				242	110.5	205		124359		



Single bossed clamps can be produced in all other pipe sizes and types according to customer specifications. For use in areas with requirements on the duration of fire resistance, the boundary conditions set out in the fire test report must be observed.